

Brown & Root Fire & Emergency Services

Taszar Support Base, Hungary

Operation Joint Forge

APO AE 09793

DSN 760-4321

DIAL 117 FOR AN EMERGENCY!



A Halliburton Company

NFPA 1500 Compliance Report

Standard Content	Remarks/Suggestions
2-1.2 Operational response criteria.	Need more details in O.I. 5.0 Emergency Response to meet this criteria.
2-3.2 Occupational Safety and Health Program Audit.	Add to O.I. 4.1 Occupational Safety and Health Program.
3-1.7 Safe exit from emergency operations.	Add to O.I. 5.0 Emergency Response.
3-2.9 All members trained at least first responder operations level.	Training in progress.
3-2.11.1 All members aware of flammability and thermal stability of clothing.	Add to Form 55.
3-4.3 Hazardous Materials Responders.	Training in progress.
4-2.6 SOP for non-emergency and emergency travel.	Add O.I./policy letter.
4-4.3 List of defects used to declare a vehicle unsafe.	Compile list.
4-5 Tools and Equipment, subsections 4-5.6 – 4-5.11. Testing and decon.	Need equipment O.I./policy letter.
5-1.4 Protective clothing cleaning every 6 months.	Need O.I./policy letter.
5-1.5 PPE cleaning.	Need O.I./policy letter.
5-1.8 Laundry service for contaminated clothing.	Work with BRS laundry to isolate FD clothing for cleaning.
5-1.8.1 Washing machines for protective or work clothing.	Requires fiscal action. Purchase machines for use in the fire department.
5-3.10 Beards and facial hair.	Add to SCBA O.I. 5.4.
5-3.11 Spectacles	Add to SCBA O.I. 5.4.
5-3.11.1 Spectacle strap or temple bars prohibited.	Add to SCBA O.I. 5.4.
5-3.11.2 Contact lens permitted.	Add to SCBA O.I. 5.4.
5-3.12 Facepiece/face seal, subsections 5-3.12.1 thru 5-3.12.4	Add to SCBA O.I. 5.4.

Standard Content	Remarks
5-4.4 Footwear and radiant reflective criteria.	Radiant reflective material for boots?
5-4.6 Radiant reflective criteria over SCBA worn outside of proximity protective clothing.	Radiant reflective material cover for SCBA?
5-5.4 NFPA 1581 Infection Control Program protective clothing cleaning.	Need guidance in writing. Add to O.I. 5.3 PPE.
6-6 Rehabilitation, subsections 6-6.1 thru 6-6.4.	Add details to O.I. 5.2. Incident Command System.
6-7 Civil unrest/terrorism	Add to O.I. 5.0 Emergency Response
7-1.1 Facility Safety-comply with codes.	Upgrade facility to meet codes or build new facility.
7-1.2 NFPA 1581 Infection Control	See 5-1.8.
7-1.4 All facilities—carbon monoxide detectors.	Requires fiscal action to purchase and install.
8-1.1 Medical evaluation and certification before becoming a member.	Work with Houston on this.
8-2 Physical performance requirements, subsections 8-2.1 thru 8-2.5.	Add O.I. covering firefighter physical performance requirements.
8-3 Physical fitness, subsections 8-3.1 thru 8-3.3.	Add O.I. covering firefighter physical fitness.
8-6 Fire department physician, subsections 8-6.1 thru 8-6.4.	Partial compliance with BRS Medical and local physicians.
9-1 Member assistance and wellness program, subsections 9-1.2 & 9-1.3.	Need written policy. May be available through BRS.

I can supply line item detail from NFPA 1500 at your request.

Regards,

Yancey D. Foster
Assistant Fire Chief/Safety Officer